



	Monthly Avg Flow, MGD	Max Wkly Flow, MGD	Inf BOD, Kg/d, Avg	Inf BOD, Kg/d, Max	Inf BOD, mg/l, Avg	Inf BOD, mg/l, Max	Fecals, Avg	Fecals, Max
January	2.285	2.497	2762	3078	300	344	4	7
February	2.339	2.444	3206	4166	327	406	3	5
March	2.285	2.578	3261	3524	323	355	4	11
April	2.297	2.255	3036	3177	307	315	4	13
May	2.518	2.821	2963	3105	282	303	7	22
June	2.370	2.859	3268	3617	314	353	7	16
July	2.629	3.098	3166	3598	302	345	7	15
August	2.455	2.713	2991	3185	288	322	13	26
September	2.103	2.131	3321	3636	350	380	6	9
October	2.064	2.075	3266	3511	352	389	4	5
November	1.993	2.170	3107	3585	358	414	3	7
December	2.441	2.660	2720	3141	271	319	3	11
<b>Avg's:</b>	<b>2.315</b>	<b>2.525</b>	<b>3089</b>	<b>3444</b>	<b>315</b>	<b>354</b>	<b>5</b>	<b>12</b>

	Tot. Res Cl <sub>2</sub> , mg/l, Max	Minimum D.O., mg/l	Eff BOD, Kg/d, Avg	Eff BOD, Kg/d, Max	Eff BOD, mg/l, Avg	Eff BOD, mg/l, Max	Eff pH, Minimum	Eff pH, Maximum
January	BDL	8.7	12.2	29.9	1.3	1.4	6.9	7.7
February	BDL	9.2	11.8	13.4	1.2	1.3	7.2	7.9
March	BDL	7.7	16.5	21.0	1.6	2.1	7.1	8.0
April	BDL	7.1	18.4	21.6	1.9	2.2	7.1	7.8
May	BDL	7.6	15.2	16.9	1.5	1.6	7.2	8.0
June	BDL	6.6	18.6	22.1	1.8	1.9	7.0	7.7
July	BDL	6.8	16.9	19.4	1.6	1.9	7.0	7.7
August	BDL	6.1	15.1	17.4	1.5	1.8	7.1	7.7
September	BDL	6.1	13.5	14.6	1.4	1.6	7.2	7.9
October	BDL	7.0	15.7	16.8	1.7	1.8	7.3	7.8
November	BDL	7.0	16.7	21.1	1.9	2.3	7.3	7.8
December	BDL	8.4	16.7	19.3	1.7	1.9	6.8	7.6
<b>Avg's:</b>	<b>BDL</b>	<b>7.4</b>	<b>15.6</b>	<b>19.5</b>	<b>1.6</b>	<b>1.8</b>	<b>7.1</b>	<b>7.8</b>

	Inf TSS, Kg/d, Avg	Inf TSS, Kg/d, Max	Inf TSS, mg/l, Avg	Inf TSS, mg/l, Max	Eff TSS, Kg/d, Avg	Eff TSS, Kg/d, Max	Eff TSS, mg/l, Avg	Eff TSS, mg/l, Max
January	1676	3332	181	362	22.2	29.9	2.4	3.2
February	2092	2927	274	384	21.1	23.3	2.2	2.6
March	1832	2398	182	248	28.6	30.9	2.8	3.0
April	1536	2768	156	283	27.0	30.2	2.7	3.1
May	1149	1483	111	145	15.6	24.7	1.5	2.3
June	3127	7550	519	1666	22.1	28.2	2.0	2.3
July	1516	2274	281	407	25.4	30.4	2.5	3.2
August	1536	2269	181	252	20.7	26.1	2.0	2.6
September	1535	2067	289	413	16.3	21.1	1.7	2.1
October	1203	1498	232	489	15.0	16.1	1.6	1.8
November	1558	2385	243	547	19.1	31.4	2.2	3.4
December	1100	1301	131	151	24.8	29.9	2.4	2.9
<b>Avg's:</b>	<b>1655</b>	<b>2688</b>	<b>232</b>	<b>446</b>	<b>21.5</b>	<b>26.9</b>	<b>2.2</b>	<b>2.7</b>

City of Cornelia, Georgia WPCP Summary DMR Data Sheet, 200 **2013** (pg 2 of 2)

	Eff Phos, Kg/d, Avg.	Eff Phos, Kg/d, Max.	Eff Phos, mg/l, Avg.	Eff Phos, mg/l, Max.	Eff NH <sub>3</sub> -N, Avg, Kg/d	Eff NH <sub>3</sub> -N, Max, Kg/d	Eff NH <sub>3</sub> -N, Avg, mg/l	Eff NH <sub>3</sub> -N, Max, mg/l
January	0.40	0.60	0.05	0.10	0.70	1.50	0.08	0.160
February	0.50	0.60	0.05	0.07	0.30	0.60	0.03	0.060
March	0.80	1.00	0.08	0.10	0.20	0.60	0.02	0.050
April	1.50	5.10	0.15	0.49	0.30	0.60	0.03	0.060
May	2.00	4.20	0.18	0.40	0.20	0.30	0.02	0.030
June	3.10	4.20	0.30	0.50	0.60	0.70	0.06	0.130
July	2.30	8.60	0.35	1.68	0.10	0.20	0.01	0.010
August	1.10	6.20	0.11	0.64	0.10	0.20	0.01	0.020
September	1.30	4.40	0.14	0.47	0.50	1.30	0.05	0.140
October	0.30	0.50	0.04	0.05	0.90	3.00	0.10	0.320
November	0.40	0.90	0.05	0.09	0.70	1.30	0.08	0.150
December	0.60	2.20	0.05	0.20	1.00	1.80	0.11	0.170
<b>Avg's:</b>	<b>1.19</b>	<b>3.21</b>	<b>0.13</b>	<b>0.40</b>	<b>0.47</b>	<b>1.01</b>	<b>0.05</b>	<b>0.108</b>

	% BOD Removal, Min	% TSS Removal, Min	ds, Sludge, Total, Dry Weight, LBS
January	99.5%	98.0%	80,580
February	99.6%	98.4%	102,440
March	99.5%	98.0%	126,620
April	99.4%	97.8%	94,100
May	99.5%	98.4%	80,400
June	99.4%	98.4%	100,520
July	99.5%	97.7%	108,700
August	99.5%	98.3%	97,940
September	99.6%	98.6%	69,440
October	99.5%	98.7%	92,500
November	99.4%	98.2%	85,666
December	99.2%	97.6%	74,400
<b>Avg's:</b>	<b>99.5%</b>	<b>98.2%</b>	<b>92776 1,113,306</b>